

April 9, 2008

LAKE SHORE BURIAL VAULT CO., INC.  
HUBERT MCQUESTION  
12780 LISBON ROAD  
BROOKFIELD WI 53005

Re: Description: SEWAGE TANKS, CONCRETE  
Manufacturer: LAKE SHORE BURIAL VAULT CO., INC.  
Product Name: SEPTIC/SEPTIC/PUMP  
Model Number(s): 2250 (3 COMPARTMENT, 680/680/890)  
(59" L.L., 12/12/16 GAL/IN., 96" MAX. DEPTH OF BURY, 653 G.P.D. WHEN USED AS A  
SEPTIC/SEPTIC/SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR  
RESIDENTIAL WASTEWATER)  
Product File No: 20080192

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of April 2013.**

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.
- This product is approved to use the following:
  - Four-inch or 8-inch opening located in interior wall and between a distance of 10-inches below liquid level and above 1/3 of liquid level above bottom of tank for septic tanks only.
  - Four-inch opening in tank or access cover.
  - Eight-inch pass-way between septic/septic and 4-inch opening through to pump chamber.
  - Four- or six-inch inlet and outlet openings.
  - Two-inch schedule 40 PVC cast in riser for electrical wiring.
  - ConSeal C-101 butyl self-sealing, flexible permanent water tight joints.
  - Pipe materials constructed in conformance with Table Comm 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover, access cover or interior wall.
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.

LAKE SHORE BURIAL VAULT CO., INC.  
Page 2  
April 9, 2008  
PRODUCT FILE NO. 20080192

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@wisconsin.gov